

City of Healdsburg



Addendum

Date:	Monday, July 22, 2024
Project Name:	Cabernet Road Culvert Replacement Project - DR002
Addendum No.	1
Issued To:	All plan holders

The following changes are hereby made to the contract documents:

ITEM 1: INFORMATION/CLARIFICATION

- 1.1 The project disturbance is less than one acre. A SWPPP is not required. Should the Contractor disturb more than one acre they shall prepare a SWPPP at no additional cost to the City.
- 1.2 The estimated quantity of Untastable Trench Overexcavation/Stabilization is provided for bidding purposes only and has been established based on the assumption that approximately 10% of the total anticipated trench subgrade area will require overexcavation/stabilization to a depth of 12". This quantity may be increased, decreased, or eliminated in its entirety based on field condition evaluation by the Engineer.

A copy of this addendum, signed by the bidder, must accompany all bids.

Authorized By

Clay Thistle

Clay Thistle Principal Engineer
City of Healdsburg

Accepted By Bidder

Name

Company