



FIRE DEPARTMENT

FIRE PREVENTION STANDARD NO. 3



Handy Lohr
DEVELOPED BY - FIRE MARSHAL

PAGE 1 OF 1

R. Taylor
APPROVED BY - FIRE CHIEF

PAST EDITIONS
NONE

DATE: August 20, 1991



FIRE LANE Sign To Be Set Per City Standard *ST10*

FIRE LANE SIGN

12" x 18"
Red on White
Reflectorized .080 Gauge

NOTES:

1. All Signs And Curb Markings Are To Be Installed And Maintained By The Property Owner.
2. Detailed Plans Of The Proposed Fire Lane Markings Shall Be Provided To The Fire Prevention Bureau For Review Prior To Installation.
3. Signs Marking FIRE LANES Are To Be Spaced So They Are Within Three (3) Feet Of Each End Of Curbed Areas And Spaced A Minimum Of One Hundred (100) Feet Apart Thereafter.
4. In Addition, One (1) Sign Is Required For Each Island Adjacent To A Fire Lane Or Access Road If The Road Width Is Less Than Twenty (20) Feet
5. Signs Are To Face Oncoming Vehicular Traffic.
6. All curbs Adjoining Fire Lanes Or Posted Areas Shall Be Painted Red And Labeled.